

## Installation Instructions:

1. This product is connected in series to the protected device.
2. Mount the SPD on 35 mm DIN rail. [optional]
3. The OUT terminal should be connected to the protected device.
4. SPD's earthing terminal must be connected to an nearby earthing busbar or the metal earthing enclosure of protected device.
5. Ensure the circuit is functioning.

\*Regularly inspect the operating status, especially after lightning.

## Installation Diagram:

